

## 2018 Consumer Confidence Report

Water System Name: Northwest Prep. School Report Date: 4/19/19

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018 and may include earlier monitoring data.*

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name Here] a [Enter Water System's Address or Phone Number Here] para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System's Name Here] 以获得中文的帮助: [Enter Water System's Address Here][Enter Water System's Phone Number Here]

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address Here] o tumawag sa [Enter Water System's Phone Number Here] para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name Here] tại [Enter Water System's Address or Phone Number Here] để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name Here] ntawm [Enter Water System's Address or Phone Number Here] rau kev pab hauv lus Askiv.

Type of water source(s) in use: Ground Water Well

Name & general location of source(s): 2590 Piner Road, Santa Rosa, Ca. Well # 01 is located near the East side of the property adjacent to the parking lot in a fenced and locked enclosure.

Drinking Water Source Assessment information: Was completed in June 2001. It may be viewed by contacting the State Water Resources Control Board, 50 D Street, Suite 200, Santa Rosa CA.

Time and place of regularly scheduled board meetings for public participation: The board meets on the first Wednesday of each month. Contact school office for further information.

For more information, contact: Tyler Judson, Weeks Water Treatment Phone: (707) 823-3184

### TERMS USED IN THIS REPORT

<p><b>Maximum Contaminant Level (MCL):</b> The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p><b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p> <p><b>Public Health Goal (PHG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p><b>Maximum Residual Disinfectant Level (MRDL):</b> The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p> <p><b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p> <p><b>Primary Drinking Water Standards (PDWS):</b> MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p>	<p><b>Secondary Drinking Water Standards (SDWS):</b> MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p> <p><b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water.</p> <p><b>Regulatory Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p><b>Variations and Exemptions:</b> State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p><b>Level 1 Assessment:</b> A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.</p> <p><b>Level 2 Assessment:</b> A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.</p> <p><b>ND:</b> not detectable at testing limit</p> <p><b>ppm:</b> parts per million or milligrams per liter (mg/L)</p> <p><b>ppb:</b> parts per billion or micrograms per liter (µg/L)</p> <p><b>ppt:</b> parts per trillion or nanograms per liter (ng/L)</p> <p><b>ppq:</b> parts per quadrillion or picogram per liter (pg/L)</p> <p><b>pCi/L:</b> picocuries per liter (a measure of radiation)</p>
--	--

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	9/7/18	5	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/7/18	5	0.39	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/9/90	26	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	11/9/90	130	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
*Nitrate (ppm)	2018	5.5	4.5-5.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Arsenic (ppb)	2/15/17	3.0	na	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Chromium (ppb)	2/9/11	3.0	na	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Hexavalent Chromium (ppb)	10/25/17	1.1	na	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
Chlorine (ppm)	2018	0.66	0.4-0.97	[MRDL = 4.0 (as Cl <sub>2</sub> )]	[MRDLG = 4 (as Cl <sub>2</sub> )]	Drinking water disinfectant added for treatment
Barium (ppm)	2/9/11	0.12	na	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits.
Gross Alpha (pCi/L)	6/8/16	0.49	na	15	(0)	Erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (TDS)(ppm)	10/25/17	350	na	1000	na	Runoff/leaching from natural deposits

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language	
None						

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at

risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Northwest Prep** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

\*Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

Northwest Prep School water system is operated under contract by Weeks Water Treatment of Sebastopol.

To inquire about the system or to report trouble, please call 707-542-3272.

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
None				

**For Water Systems Providing Ground Water as a Source of Drinking Water**

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 0		0	(0)	Human and animal fecal waste
Enterococci	(In the year) 0		TT	n/a	Human and animal fecal waste
Coliphage	(In the year) 0		TT	n/a	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Ground Water TT**

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLE
None
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES
None

<b>VIOLATION OF GROUND WATER TT</b>				
<b>TT Violation</b>	<b>Explanation</b>	<b>Duration</b>	<b>Actions Taken to Correct the Violation</b>	<b>Health Effects Language</b>
<b>None</b>				